

Wyoming Statute Title 35
Chapter 11
Article 14
(Section 1)

Also known as the Storage Tank Act of 2007

Page 2

Wyoming Statute Title 35
Chapter 11
1414

Wyoming Statute Title 35
Chapter 11
1415

Example Question 1

Which of the following tanks is not a regulated tank?

- a. A farm UST that contains 2,000 gallons
- b. A 2,000 gallon underground emergency power generator tank
- c. An aboveground tank used by a dealer to dispense gasoline
- d. A septic tank

WS 35-11-1415(a)(ix)(C)

Example Question 2

Which of the following tanks is a regulated tank?

- a. A farm tank that contains 500 gallons**
- b. An oil/water separator**
- c. A 1,000 gallon UST used to store used oil**
- d. Hydraulic lift tank**

WS 35-11-1415(a)(ix) (A)

WS 35-11-1415(a)(ix)(F)

WS 35-11-1415(a)(ix)(Q)

Wyoming Statute Title 35
Chapter 11
1416-1420

Example Question 3

Which of the following information is not required to be submitted to the department?

- a. The name, address and telephone number of the owner
- b. The type of dispensers used at a facility
- c. The type and age of each tank at the facility
- d. The most recent date the tank was tested

WS 35-11-1419(a)(i)

WS 35-11-1415(a)(iv)

WS 35-11-1415(a)(viii)

Example Question 4

An owner of over 100 tanks is required to show proof of financial responsibility for a minimum of?

- a. \$200
- b. \$200,000
- c. \$2,000,000
- d. \$20,000,000

WS 35-11-1419(a)(x)

Example Question 5

An owner must give prior notification of at least how many days prior to installing, or substantially modifying a tank system?

- a. 1 days
- b. 7 days
- c. 14 days
- d. 30 days

WS 35-11-1420(b)

Example Question 6

How much money should the department collect for a installation or modification fee?

- a. \$50
- b. \$200
- c. \$250
- d. \$500

WS 35-11-1420(c)

Wyoming Statute Title 35
Chapter 11
1421-1425

Example Question 7

How much notice must the department give prior to an investigation, unless an emergency exists?

- a. 24 hours
- b. 7 working days
- c. 30 days
- d. 30 working days

WS 35-11-1422(e)

Example Question 8

The department may use funds from the corrective action account for which of the following tasks?

- a. Tank repairs**
- b. Pay legal fees**
- c. Take corrective action in response to a release**
- d. Payment of a judgment involving a third party impact**

WS 35-11-1424(a)

Example Question 9

What is the late payment fee for a 4,000 gallon retail AST?

- a. \$50
- b. \$100
- c. \$200
- d. \$250

WS 35-11-1425(b) Note: The original fee was \$50

Wyoming Statute Title 35
Chapter 11
1426-1429

Example Question 10

An owner had a leak from a regulated tank. He has a third party judgment against him for \$2,100,000 how much of the judgment would be initially paid by the financial responsibility account?

- a. \$100,000
- b. \$1,000,000
- c. \$2,000,000
- d. \$2,100,000

WS 35-11-1428(c)

Example Question 11

An owner had a leak from a regulated tank. He has a judgment against him for \$1,000,000. How much of the judgment would he ultimately be responsible to pay?

- a. \$50
- b. \$200
- c. \$30,000
- d. \$1,000,000

WS 35-11-1428(c)(i)

Example Question 12

A truck stop that sells 1,000,000 gallons of gasoline a month. The single wall tanks at the facility were installed in 1985 when do they have to replace the tanks with double wall tanks?

- a. 2005
- b. 2012
- c. 2015
- d. 2025

WS 35-11-1429(b)