

## General Information

Public Record Posted Date: 10/7/2009

Total Number of UST Facilities: 745

Total Number of USTs: 1918

## Summary Information for On-Site Inspections

Number of UST Facilities Inspected: 263

Inspection Period Dates: 10/1/2008 to 9/30/2009

Percent Compliance (Combined Measure): 82.51

Note: Tanks, facility, and on-site inspection information is based on the number of federally regulated USTs that are currently in use or temporarily out of use. On-Site inspections measure compliance with SOC-3 (SOC-1 and/or SOC 2) standards.

## Summary Information for Releases

Number of Confirmed Releases: 40

Release Reporting Period Dates: 10/1/2008 to 9/30/2009

## Summary Information for Release Sources and Causes

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	7	17.5 %	0	0.0 %	0	0.0 %	0	0.0 %	1	2.5 %	2	5.0 %	0	0.0 %	4	10.0 %
Piping	8	20.0 %	0	0.0 %	0	0.0 %	4	10.0 %	0	0.0 %	4	10.0 %	0	0.0 %	0	0.0 %
Dispenser	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %
STP	1	2.5 %	0	0.0 %	0	0.0 %	1	2.5 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %
Delivery Problem	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %
Other	13	32.5 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	13	32.5 %
Unknown	11	27.5 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	11	27.5 %
Totals	40	100.0 %	0	0.0 %	0	0.0 %	5	12.5 %	1	2.5 %	6	15.0 %	0	0.0 %	28	70.0 %

# = number, % = percent of total number

Note: Release, source, and cause information is based on the number of federally regulated USTs. Source and cause data were collected using inspection records.

Site-specific UST compliance and release information can be obtained by contacting the Wyoming Department of Environmental Quality Solid and Hazardous Waste Division:

phone 307-777-7752

email [blucht@wyo.gov](mailto:blucht@wyo.gov) or [ogilbr@wyo.gov](mailto:ogilbr@wyo.gov)