

**Wyoming Department of Environmental Quality  
Water Quality Division  
WYPDES (Wyoming Pollutant Discharge Elimination System) Program**

STATEMENT OF BASIS

MAJOR MODIFICATION

APPLICANT NAME: Kemmerer-Diamondville Joint Powers Board

MAILING ADDRESS: PO Box 1020  
Kemmerer, WY 83101-1020

FACILITY LOCATION: Kemmerer Wastewater Treatment, which is located in SW Section 13, Township 21N, Range 116W, Latitude 41.79396, Longitude -110.53457, Lincoln County. The wastewater will be discharged to Hams Fork River (2AB) Green River Basin.

PERMIT NUMBER: WY0020320

***This permit has been modified in accordance with current WYPDES permitting requirements. All permit effluent limits and monitoring requirements have been updated in accordance with current WDEQ regulations and policy. Specific changes to the permit include the following:***

1. *This permit adds one outfall, 002, which involves discharge of water from an emergency bypass line. This outfall includes the same effluent limits as the standard outfall, 001. Because the emergency bypass discharge is rarely expected, outfall 002 is not included in the 366 tons per year incremental TDS calculation. Furthermore, percent removal limits of TDS and BOD are not included for outfall 002, but the 30 mg/L monthly average, 45 mg/L weekly average, and 90 mg/L daily maximum limits apply for BOD and TSS.*
2. *This permit modification institutes a 366 tons per year of incremental increase TDS in place of the 400 mg/L incremental TDS limit, to go into effect immediately. The facility currently meets the 366 tons of TDS per year standard.*
3. *The facility will likely not meet the 366 tons per year limit in the event of a major population increase or in the event of unpredictable factors that may raise the TDS load discharging into the receiving water. This permit therefore includes a compliance schedule for development of a cost-benefit analysis for TDS removal from the wastewater stream, consistent with all WYPDES permits in the Colorado River Basin where there may be a compliance problem with the TDS. TDS removal must be implemented by May 31, 2013 if economically feasible.*
4. *DEQ can provide the spreadsheets shown by Table B and Table C to the permittee for ease in calculations of tons per year and the flow weighted incremental TDS concentration.*
5. *This permit requires monitoring of the yearly flow-weighted incremental increase TDS in mg/L. Refer to Table C, statement of basis for an example of the calculation.*

**BACKGROUND:** The Kemmerer-Diamondville Water and Wastewater Joint Powers Board is responsible for providing water and sewer service for the towns of Kemmerer and Diamondville, Wyoming. The wastewater treatment facilities consist of a bar screen, grit removal equipment, an oxidation ditch followed by two final clarifiers, and chlorination and dechlorination facilities. The plant discharges to the Hams Fork River, class 2AB water.

The facility discharges to the Colorado River Basin. The existing permit includes a monthly limit on the incremental TDS difference of 400 mg/L in compliance with the 2005 Review of the Water Quality Standards for Salinity, Colorado River System. The Colorado River Basin Salinity Forum allows either 400 mg/L yearly flow-weighted incremental increase TDS or 366 tons per year limit on incremental TDS. Incremental TDS increase is described as the difference in the TDS of the 1) potable water supply intake prior to any treatment AND 2) of the sewage treatment plant effluent, i.e., the increase between 1) and 2).

The facility currently meets the tons per year limit of 366 tons TDS per year. For example, the incremental increase of TDS load during calendar year 2010 was 307 tons. With an increase in discharge or because of unpredictable factors that may raise the TDS above 366 tons per year, this permit requires that the facility develop a cost-benefit analysis for reducing TDS, and to implement reduction of the TDS if economically feasible.

**MAJOR DISCHARGER:** The plant is classified as a “major” discharger per the U.S. Environmental Protection Agency. The permit will be submitted to the U.S. Environmental Protection Agency, Region 8 for review.

**SAME TERMS AND CONDITIONS:** With the exception of items explicitly delineated in this statement of basis, all terms and conditions of permit WY0020320 shall remain unchanged and in full force and effect.

Self monitoring of effluent quality and quantity is required on a regular basis with reporting of results monthly. The permit is scheduled to expire on June 30, 2013.

Roland Peterson  
Water Quality Division  
Department of Environmental Quality  
Drafted: March 7, 2011

Table A

Wasteload Allocation (WLA) Calculations *, Hams Fork												
Facility:	City of Kemmerer											
Permit Num	WY0020320	Wasteload Allocation Formula:				$C_d = (Q_r C_r - Q_s C_s) / Q_d$						
		$Q_s$	$Q_d$	$Q_r$	$C_r$	$C_s$	$C_d$					
Season	Parameter	Low Flow, cfs (7Q10)	Low Flow, MGD (7Q10)	Discharge Rate, MGD	Combined Flow, MGD	Water Quality Standard, Chronic	Background Con. (LA)	Limit (WLA)	Pounds Per Day (WLA)	Pounds Per Day (LA)	Pounds Per Day (TMDL)	
May - Sept	TRC, chronic	0.69	0.45	0.75	1.20	0.011	0	<b>0.02</b>	0.11	0.00	0.11	
Oct - April	TRC, chronic	0.767	0.49	0.75	1.24	0.011	0	<b>0.02</b>	0.11	0.00	0.11	
Season	Parameter	Low Flow, cfs (7Q10)	MGD (7Q10)	Discharge Rate, MGD	Combined Flow, MGD	Standard, Acute	Background Con. (LA)	Limit (WLA)	Pounds Per Day (WLA)	Pounds Per Day (LA)	Per Day (TMDL)	
May - Sept	TRC, acute	0.69	0.45	0.75	1.20	0.019	0	0.03	0.19	0.00	0.19	
Oct - April	TRC, acute	0.77	0.49	0.75	1.24	0.019	0	0.03	0.20	0.00	0.20	
Season	Parameter	Low Flow, cfs (7Q10)	Low Flow, MGD (7Q10)	Discharge Rate, MGD	Combined Flow, MGD	Water Quality Standard, Monthly Avg.	Background Con. (LA)	Limit (WLA)	Number per day (WLA)			
April - Sept	E.coli, #/100 ml	0.69	0.45	0.75	1.20	126	30	<b>183</b>	4.799E+09			
Oct - March	E. coli #/100 ml	0.77	0.49	0.75	1.24	630	30	<b>1026</b>	2.974E+10			
Season	Parameter	Low Flow, cfs (7Q10)	Low Flow, MGD (7Q10)	Discharge Rate, MGD	Combined Flow, MGD	Water Quality Standard, Daily Max.	Background Con. (LA)	Limit (WLA)	Number per day (WLA)			
April - Sept	E.coli, #/100 ml	0.69	0.45	0.75	1.20	576	30	<b>901</b>	2.361E+10			
Oct - March	E.coli, #/100 ml	0.77	0.49	0.75	1.24	630	30	<b>1026</b>	2.974E+10			
Season	Parameter	Low Flow, cfs (7Q10)	Low Flow, MGD (7Q10)	Discharge Rate, MGD	Combined Flow, MGD	Water Quality Standard, Chronic	Background Con. (LA)	Limit (WLA)	Pounds Per Day (WLA)	Pounds Per Day (LA)	Pounds Per Day (TMDL)	
May - Sept	Ammonia, chronic	0.69	0.45	0.75	1.20	0.7	0.1	<b>1.06</b>	6.62	0.37	6.99	
Oct - April	Ammonia, chronic	0.77	0.49	0.75	1.24	1.29	0.1	<b>2.07</b>	12.98	0.41	13.39	
Season	Parameter	Low Flow, cfs (7Q10)	MGD (7Q10)	Discharge Rate, MGD	Combined Flow, MGD	Standard, Acute	Background Con. (LA)	Limit (WLA)	Pounds Per Day (WLA)	Pounds Per Day (LA)	Per Day (TMDL)	
May - Sept	Ammonia, acute	0.69	0.45	0.75	1.20	2.59	0.1	4.07	25.48	0.37	25.86	
Oct - April	Ammonia, acute	0.77	0.49	0.75	1.24	2.59	0.1	4.23	26.47	0.41	26.89	

\*All units are mg/l, unless otherwise specified.

Effluent Limits Are Shaded, In Bold

**Table B**

<b>City of Kemmerer Tons of Incremental TDS Calendar Year 2010</b>					
<b>Month</b>	<b>Avg Daily Flow, MGD</b>	<b>Avg Inc. TDS, mg/L</b>	<b>TDS Pounds per Day</b>	<b>TDS Pounds Per Month</b>	<b>TDS Tons Per Month</b>
January	0.353	454	1336.585	41434.14	20.71707
February	0.329	477	1308.821	36646.99	18.3235
March	0.371	471	1457.34	45177.54	22.58877
April	0.322	657	1764.36	58223.89	29.11195
May	0.398	569	1888.693	58549.49	29.27474
June	0.391	802	2615.274	78458.22	39.22911
July	0.342	636	1814.05	56235.55	28.11778
August	0.355	506	1498.114	46441.54	23.22077
September	0.339	548	1549.338	46480.15	23.24008
October	0.321	531	1421.561	44068.4	22.0342
November	0.321	497	1330.539	39916.16	19.95808
December	0.375	634	1982.835	61467.89	30.73394
<b>Year 2010 Total, Tons=</b>					<b>307</b>

This demonstration shows compliance with the 366 tons per year limit on TDS for the calendar year 2010.

**Table C**

	From DMR	Average flow X days in the month	From DMR	Fraction of flow (Monthly Total Flow ÷ Annual Total Flow)	Incremental TDS multiplied by fraction of flow	
	<b>Average Monthly Flow, MGD</b>	<b>Total Monthly Flow, million gallons</b>	<b>Incremental TDS, mg/l</b>	<b>Fraction of flow</b>	<b>Flow-weighted TDS Average, mg/l</b>	
January	0.353	10.943	454	0.085247766	38.70	
February	0.329	9.212	477	0.071762992	34.23	
March	0.371	11.501	471	0.089594678	42.20	
April	0.322	9.66	657	0.075252986	49.44	
May	0.398	12.338	569	0.096115045	54.69	
June	0.391	11.73	802	0.091378625	73.29	
July	0.342	10.602	636	0.08259132	52.53	
August	0.355	11.005	506	0.085730756	43.38	
September	0.339	10.17	548	0.079225969	43.42	
October	0.321	9.951	531	0.077519923	41.16	
November	0.321	9.63	497	0.075019281	37.28	
December	0.375	11.625	634	0.090560658	57.42	
<b>Annual Total</b>		<b>128.367</b>	565.17	<b>1.000000</b>	<b>567.74</b>	<b>mg/L</b>
<b>Flow-Weighted TDS Average for Entire Year, mg/l</b>	<b>568 mg/L</b>					

Yellow shaded areas indicate cells where data entry is required on the spreadsheet. Non-shaded areas have formula driven results.

AUTHORIZATION TO DISCHARGE UNDER THE  
WYOMING POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Water Pollution Control Act, (hereinafter referred to as "the Act"), and the Wyoming Environmental Quality Act,

Kemmerer-Diamondville Joint Powers Board

is authorized to discharge from the Kemmerer Wastewater Treatment facilities located in

SW Section 13, Township 21N, Range 116W,  
Latitude 41.79396, Longitude -110.53457, Lincoln County


to receiving waters named

Hams Fork River (2AB), Green River Basin


in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II and III hereof.

This permit shall become effective on the date of signature by the Director of the Department of Environmental Quality.

This permit and the authorization to discharge shall expire on June 30, 2013 at midnight.

  
\_\_\_\_\_  
John F. Wagner, Administrator  
Water Quality Division

6/3/11  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
John V. Corra  
Director - Department of Environmental Quality

6/6/11  
\_\_\_\_\_  
Date

PART I

A. EFFLUENT LIMITATIONS

Effective immediately and lasting through June 30, 2013, the quality of effluent discharged by the permittee shall, at a minimum, meet the limitations set forth below. The permittee is authorized to discharge from outfall serial number(s) 001-002.

1. Such discharges shall be limited as specified below:

<u>Parameter</u>	<u>Effluent Concentration</u>		
	<u>Monthly Average (b)</u>	<u>Weekly Average (b)</u>	<u>Daily Maximum(a) (b)</u>
Ammonia, total as N, mg/L, May thru Sept	1.06	N/A	4.07
Ammonia, total as N, mg/L, Oct through April	2.07	N/A	4.23
Biochemical Oxygen Demand (BOD), mg/L	30	45	90
BOD , % Removal (d), outfall 001 only	85	N/A	N/A
E. coli, colonies/100 ml, April through Sept	183	N/A	901
E. coli, colonies/100 ml, Oct through March	1026	N/A	1026
Flow, MGD	0.75	N/A	N/A
pH (standard units) (c)	N/A	N/A	6.5 to 9.0
Total Dissolved Solids, incremental increase, tons per year	366	N/A	N/A
Total Residual Chlorine, mg/L	N/A	N/A	0.03
Total Suspended Solids (TSS) , mg/L	30	45	90
TSS, % Removal (d), outfall 001 only	85	N/A	N/A

Samples taken to determine compliance with the effluent limitations specified above shall be taken at the outfall from the final treatment unit and prior to admixture with diluent waters or the receiving stream.

- (a) Any single analysis and/or measurement beyond this limitation shall be considered a violation of the conditions of this permit.
- (b) Monthly Average, Weekly Average and Daily Maximum are defined in Part I.C.3.
- (c) The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units in any single grab sample.
- (d) Compliance with percent removal requirements is based on 30-day average sampling. More frequent sampling is optional. The arithmetic mean of the BOD concentration for effluent samples collected in a period of 30-day average shall demonstrate a minimum of

eighty-five percent (85%) removal of BOD, as measured by dividing the respective differences between the mean influent and effluent concentrations for the calendar month by the respective mean influent concentration for the 30-day average, and multiplying the quotient by 100. See figure below.

$$\left[ \frac{\text{Influent} - \text{Effluent}}{\text{Influent}} \right] \times 100$$

There shall be no discharge of floating solids or foam in other than trace amounts. Nor shall the discharge have a visible sheen or cause formation of a visible sheen or visible deposits on the bottom or shoreline of the receiving water.

All waters shall be discharged in a manner to prevent erosion, scouring, or damage to stream banks, stream beds, ditches, or other waters of the state at the point of discharge. Discharges shall not occur in such a manner that will result in violations of Water Quality Rules and Regulations, Chapter 1, Section 15. In addition, there shall be no deposition of substances in quantities which could result in significant aesthetic degradation or degradation of habitat for aquatic life, plant life or wildlife; or which could adversely affect public water supplies or those intended for agricultural or industrial use.

**B. SELF-MONITORING REQUIREMENTS**

1. Effective immediately and lasting through June 30, 2013, the permittee shall monitor this discharge(s) as shown below for outfall 001:

<u>Parameter</u>	<u>Frequency (a)</u>	<u>Sample Type (b)</u>
E. coli, colonies/100 ml	5-times-monthly(c)	Grab
pH, units	Weekly	Grab
BOD, influent, mg/L	Weekly	Grab
BOD, effluent, mg/L	Weekly	Composite
BOD, % Removal	Weekly	Calculated
Flow, MGD	Weekly	Continuous
Total Residual Chlorine, mg/L (d)	Daily	Grab
TSS, influent, mg/L	Weekly	Grab
TSS, effluent, mg/L	Weekly	Composite
TSS, % Removal	Weekly	Calculated
Ammonia, mg/L	Weekly	Composite
Total Dissolved Solids, mg/L, potable water intake	Monthly	Composite
Total Dissolved Solids, mg/L, effluent	Monthly	Composite
Total Dissolved Solids, mg/L, effluent minus potable water intake supply	Monthly	Calculated

<u>Parameter</u>	<u>Frequency (a)</u>	<u>Sample Type (b)</u>
Total Dissolved Solids, mg/L, flow weighted average for calendar year	Annually	Calculated
Total Dissolved Solids, tons per calendar month	Monthly	Calculated
Total Dissolved Solids, tons per year	Annually	Calculated

2. Effective immediately and lasting through June 30, 2013, the permittee shall monitor this discharge(s) as shown below for outfall 002:

<u>Parameter</u>	<u>Frequency (a)</u>	<u>Sample Type (b)</u>
E. coli, colonies/100 ml	Weekly	Grab
pH, units	Weekly	Grab
BOD, effluent, mg/L	Weekly	Grab
Flow, MGD	Weekly	Instantaneous
TSS, effluent, mg/L	Weekly	Grab
Ammonia, mg/L	Weekly	Grab
Total Dissolved Solids, mg/L, effluent	Weekly	Grab

- (a) If the discharge occurs on an intermittent basis, samples shall be collected during the period when that intermittent discharge occurs.
  - (b) See "definitions" under the Monitoring and Reporting portion of this permit.
  - (c) During each month, five samples must be collected. Samples shall be collected on a weekly basis, except for those months that have four weeks. In this case, the fifth sample shall be collected during the second or third weeks of the month and analyzed anytime during the month.
  - (d) Monitor only if chlorine is used in the wastewater treatment process.
2. Effluent Limitations (Toxic Pollutants)

Effective calendar year 2011 there shall be no acute toxicity in the discharge from outfall number 001

3. Whole Effluent Testing

Starting in the third quarter of calendar year 2011, the permittee shall, at least once each calendar quarter, conduct acute static replacement toxicity tests on a grab sample of the discharge. Quarterly samples shall be collected on a two (2) day progression; i.e., if the first quarterly sample is on a Monday, during the next quarter, sampling shall begin on a Wednesday, etc.

The replacement static toxicity tests shall be conducted in accordance with the procedures set out in accordance with the latest procedures set forth in 40 CFR 136.3 and the "Region VIII EPA NPDES Acute Test Conditions - Static Renewal Whole Effluent Toxicity Tests". In the case of conflicts, the 40 CFR 136.3 document will prevail. The permittee shall conduct an acute 48-hour static toxicity test using *Ceriodaphnia dubia* and an acute 96-hour static toxicity test using *Pimephales promelas*.

Acute toxicity occurs when 50 percent or more mortality is observed for either species at any effluent concentration. If more than 10 percent control mortality occurs, the test is not valid. The test shall be repeated until satisfactory control survival is achieved.

If acute toxicity occurs, an additional test shall be conducted within two (2) weeks of the date of when the permittee learned of the test failure. If only one species fails, retesting may be limited to this species. Should acute toxicity occur in the second test, testing shall occur once a month until further notified by the permit issuing authority.

Quarterly test results shall be reported along with the Discharge Monitoring Report (DMR) submitted for the end of the reporting calendar quarter (e.g., whole effluent results for the calendar quarter ending March 31, shall be reported with the DMR due April 28, with the remaining reports submitted with DMRs due each July 28, October 28 and January 28). Monthly test results shall be reported along with the DMR submitted for that month. The format for the report shall be consistent with the latest revision of the "Region VIII Guidance for Acute Whole Effluent Reporting", and shall include all chemical and physical data as specified.

If the results for four consecutive quarters of testing indicate no acute toxicity, the permittee may request the permit issuing authority to allow a reduction to quarterly acute toxicity testing on only one species on an alternating basis. The permit issuing authority may approve or deny the request based on the results and other available information without an additional public notice. If the request is approved, the test procedures are to be the same as specified above for the test species.

4. Toxicity Reduction Evaluation (TRE)  
Toxicity Identification Evaluation (TIE)

Should acute toxicity and/or chronic toxicity be detected in the permittee's discharge, a TIE-TRE shall be undertaken by the permittee to establish the cause of the toxicity, locate the source(s) of the toxicity, and develop control of, or treatment for the toxicity. Failure to initiate, or conduct an adequate TIE-TRE, or delays in the conduct of such tests, shall not be considered a justification for noncompliance with the whole effluent toxicity limits contained in Part I.C.1. of this permit. A TRE plan needs to be submitted to the permitting authority within 45 days after confirmation of the continuance of effluent toxicity.

5. Chronic Toxicity Limitation-Reopener Provision

This permit may be reopened and modified (following proper administrative procedures) to include chronic whole effluent toxicity limitations if any other information or data are developed indicating that chronic whole effluent toxicity limits are needed as required under 40 CFR 122.44 (d). Also see Part IV.P. of this permit for additional whole effluent toxicity reopener provisions.

If acceptable to the permit issuing authority, and if in conformance with current regulations, this permit may be reopened and modified to incorporate TRE conclusions relating to additional numerical limitations, a modified compliance schedule, and or modified whole effluent protocol.

C. COMPLIANCE SCHEDULE, TOTAL DISSOLVED SOLIDS, (TDS)

According to the 2008 Review of the Water Quality Standards for Salinity, Colorado River System, municipal discharges may not exceed an incremental increase in total dissolved solids of 366 tons per year above the flow weighted average salinity of the intake water supply. Based on discharge monitoring reports previously submitted by the facility, the facility may exceed this limit with a major population increase or unpredictable factors that may raise the incremental TDS load discharging into the receiving water. Another option is meeting a 400 mg/L incremental increase limit based on flow weighted average salinity, but the facility is consistently exceeding this limit. Therefore, this permit establishes the following compliance schedule:

1. By June 30, 2012, the operator shall provide written demonstration, by means of a cost-benefit analysis, if it is economically practical to attain either the 400 mg/L or the 366 tons per year limit on the incremental TDS. Refer to the 2005 Review referenced above for a detailed description of the information that must be included in the demonstration. The permittee is in the process of investigating possible sources of TDS increase. The cost benefit analysis should include costs involved with eliminating the sources of TDS as well as the cost of treating the wastewater to decrease TDS. If economically feasible, the upgrades for TDS treatment shall be implemented by May 31, 2013.

D. MONITORING AND REPORTING

1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other wastestream, body of water, or substance. Monitoring points shall not be changed without notification to and approval by, the permit issuing authority. Sludge samples shall be collected immediately prior to the disposal practice at a location representative of the sludge.

2. Reporting

Effluent monitoring results obtained during the previous one month(s) shall be summarized and reported on a Discharge Monitoring Report Form. If the permit requires whole effluent toxicity (WET) (biomonitoring) testing, WET test results must be reported on the most recent version of EPA Region 8 Guidance for Whole Effluent Reporting. Legible copies of these, and all other reports required herein, shall be signed and certified in accordance with the Signatory Requirements (see Part II.A.11.), and submitted to the state water pollution control agency at the following address. The reports must be received by the agency no later than the 28th day of the month following the completed reporting period. The first report is due on July 28, 2011.

Wyoming Department of Environmental Quality-Water Quality Division Herschler Building, 4 West 122 West 25th Street Cheyenne, WY 82002 Telephone: (307) 777-7781	Policy, Enforcement Management and Environmental Justice Program (ENF-PJ) ATTN: NPDES Enforcement U.S. EPA, Region 8 1595 Wynkoop St. Denver, CO 80202-1129 Telephone: (303) 293-1622
---	---

If no discharge occurs during the reporting period, "no discharge" shall be reported. If discharge is intermittent during the reporting period, sampling shall be done while the facility is discharging.

3. Definitions

Concentration Values

- a. Daily Maximum (mg/L) - The highest single reading from any grab or composite sample collected during the reporting period.
- b. Monthly Average (mg/L) - The arithmetic mean (geometric mean in the case of fecal coliform) of all composite and/or grab samples collected during a calendar month.
- c. Weekly Average (mg/L) - The arithmetic mean (geometric mean in the case of fecal coliform) of all composite and/or grab samples collected during any week. A week begins at 12:01 am Sunday morning and ends at 12:00 midnight Saturday evening.

Quantity Values

- d. Daily Maximum - The highest single daily quantity reading (see Calculations below) recorded during the reporting period.
- e. Monthly Average - The arithmetic mean (geometric mean in the case of fecal coliform bacteria) of all the daily quantity readings (see Calculations below) recorded during a calendar month.
- f. Weekly Average - The arithmetic mean (geometric mean in the case of fecal coliform bacteria) of all the daily quantity readings (see Calculations below) recorded during a week. A week begins at 12:01 am Sunday morning and ends at 12:00 midnight Saturday evening.

Flow Values

- g. Daily Flow - The flow volume recorded on any single day. The daily flow volume may be determined by using an instantaneous reading (if authorized by this permit) or a continuous recorder.

- h. Monthly Average Flow - The arithmetic mean of all daily flow values recorded during a calendar month.
- i. Weekly Average Flow - The arithmetic mean of all daily flow values recorded during a week. A week begins at 12:01 am on Sunday morning and ends at 12:00 midnight Saturday evening.

Calculations

- j. Daily Quantity (kg/day) - The quantity, in kilograms per day, of pollutant discharged on a single day. The Daily quantity shall be calculated by multiplying the composite or grab sample concentration value for that day in milligrams/liter (mg/L) times the flow volume (in millions of gallons per day - MGD) for that day times 3.78. If a flow volume reading for the day the sample is collected is not available, the average flow volume reading for the entire reporting period shall be used.
- k. Daily Quantity (#/day) - The quantity, in number per day, of bacteria or other pollutants discharged on a single day. The number per day shall be calculated by multiplying the composite or grab sample result for that day, in number per 100 milliliters (#/100 ml), times the flow volume (in millions of gallons per day - MGD) times  $3.78 \times 10^7$ . If a flow volume reading for the day the sample is collected is not available, the average flow volume reading for the entire reporting period shall be used.
- l. Geometric Mean - Calculated in accordance with the procedure described in the most recent edition of "Standard Methods for the Examination of Water and Wastewater".

Miscellaneous

- m. A "composite" sample, for monitoring requirements, is defined as a minimum of four (4) grab samples collected at equally spaced two (2) hour intervals and proportioned according to flow.
- n. An "instantaneous" measurement for monitoring requirements is defined as a single reading, measurement, or observation.
- o. "MGD", for monitoring requirements, is defined as million gallons per day.
- p. "Net" value, if noted under Effluent Characteristics, is calculated on the basis of the net increase of the individual parameter over the quantity of that same parameter present in the intake water measured prior to any contamination or use in the process of this facility. Any contaminants contained in any intake water obtained from underground wells shall not be adjusted for as described above and, therefore, shall be considered as process input to the final effluent. Limitations in which "net" is not noted are calculated on the basis of gross measurements of each parameter in the discharge, irrespective of the quantity of those parameters in the intake waters.

- q. A "pollutant" is any substance or substances which, if allowed to enter surface waters of the state, causes or threatens to cause pollution as defined in the Wyoming Environmental Quality Act, Section 35-11-103.

4. Test Procedures

Test procedures for the analysis of pollutants, collection of samples, sample containers, sample preservation, and holding times, shall conform to regulations published pursuant to 40 CFR, Part 136, unless other test procedures have been specified in this permit.

5. Recording of Results

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- a. The exact place, date and time of sampling;
- b. The dates and times the analyses were performed;
- c. The person(s) who performed the analyses and collected the samples;
- d. The analytical techniques or methods used; and
- e. The results of all required analyses including the bench sheets, instrument readouts, computer disks or tapes, etc., used to determine the results.

6. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified above, the results of such monitoring shall be included in the calculation and reporting of the values required in the Discharge Monitoring Report Form. Such increased frequency shall also be indicated.

7. Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the administrator at any time. Data collected on site, copies of Discharge Monitoring Reports and a copy of this WYPDES permit must be maintained on site during the duration of activity at the permitted location.

8. Penalties for Tampering

The Act provides that any person who falsifies, tampers with or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or both.

Table 1, Outfalls  
Kemmerer Wastewater Treatment  
WY0020320

Outfall	Qtr/Qtr	Section	Township	Range	Latitude	Longitude	Receiving Water
001*	SW	13	21N	116W	41.79396	-110.53457	Hams Fork River (2AB), Green River Basin
002	SW	13	21N	116W			Hams Fork River (2AB), Green River Basin

\*Asterisk denotes outfalls for which WDEQ has field-verified the latitude and longitude locations. These are considered to be the most accurate location data available for these outfalls, and will supersede latitude and longitude values presented in the application.

83435-doc  
08/02

PART II

A. MANAGEMENT REQUIREMENTS

1. Changes

The permittee shall give notice to the administrator of the Water Quality Division as soon as possible of any physical alterations or additions to the permitted facility. Notice is required when:

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as determined in 40 CFR 122.29 (b); or
- b. The alteration or addition could change the nature or increase the quantity of pollutants discharged.

2. Noncompliance Notification

- a. The permittee shall give advance notice of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- b. The permittee shall report any noncompliance which may endanger health or the environment as soon as possible, but no later than 24 hours from the time the permittee first became aware of the circumstances. The report shall be made to the Water Quality Division, Wyoming Department of Environmental Quality at (307) 777-7781.
- c. For any incidence of noncompliance, including noncompliance related to non-toxic pollutants or non-hazardous substances, a written submission shall be provided within five (5) days of the time that the permittee becomes aware of the noncompliance circumstance.

The written submission shall contain:

- (1) A description of the noncompliance and its cause;
  - (2) The period of noncompliance, including exact dates and times;
  - (3) The estimated time noncompliance is expected to continue if it has not been corrected; and
  - (4) Steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance.
- d. The following occurrences of unanticipated noncompliance shall be reported by telephone to the Water Quality Division, Watershed Management Section, WYPDES Program (307) 777-7781 as soon as possible, but no later than 24 hours from the time the permittee first became aware of the circumstances.

- (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
  - (2) Any upset which exceeds any effluent limitation in the permit; or
  - (3) Violation of a maximum daily discharge limitation for any toxic pollutants or hazardous substances, or any pollutants specifically identified as the method to control a toxic pollutant or hazardous substance listed in the permit.
- e. The administrator of the Water Quality Division may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Water Quality Division, WYPDES Program (307) 777-7781.
- f. Reports shall be submitted to the Wyoming Department of Environmental Quality at the address in Part I under Reporting and to the Planning and Targeting Program, 8ENF-PT, Office of Enforcement, Compliance, and Environmental Justice, U.S. EPA Region 8, 1595 Wynkoop Street, Denver, CO 80202-1129.
- g. The permittee shall report all instances of noncompliance that have not been specifically addressed in any part of this permit at the time the monitoring reports are due.

3. Facilities Operation

The permittee shall, at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of the permit. However, the permittee shall operate, as a minimum, one complete set of each main line unit treatment process whether or not this process is needed to achieve permit effluent compliance.

4. Adverse Impact

The permittee shall take all reasonable steps to minimize any adverse impact to waters of the state resulting from noncompliance with any effluent limitations specified in this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

5. Bypass of Treatment Facilities

- a. Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
- b. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of

paragraphs c. and d. of this section. Return of removed substances to the discharge stream shall not be considered a bypass under the provisions of this paragraph.

c. Notice:

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice at least 60 days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required under Part II.A.2.

d. Prohibition of bypass.

- (1) Bypass is prohibited and the administrator of the Water Quality Division may take enforcement action against a permittee for a bypass, unless:
  - (a) The bypass was unavoidable to prevent loss of life, personal injury or severe property damage;
  - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
  - (c) The permittee submitted notices as required under paragraph c. of this section.

- e. The administrator of the Water Quality Division may approve an anticipated bypass, after considering its adverse effects, if the administrator determines that it will meet the three conditions listed above in paragraph d. (1) of this section.

6. Upset Conditions

- a. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improper designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- b. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of paragraph c. of this section are met.

- c. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that:
- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated;
  - (3) The permittee submitted notice of the upset as required under Part II.A.2; and
  - (4) The permittee complied with any remedial measures required under Part II.A.4.
- d. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

7. Removed Substances

Solids, sludges, filter backwash or other pollutants removed in the course of treatment or control of wastewaters or intake waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering waters of the state.

8. Power Failures

In order to maintain compliance with the effluent limitations and prohibitions of this permit, the permittee shall either:

- a. In accordance with a schedule of compliance contained in Part I, provide an alternative power source sufficient to operate the wastewater control facilities; or
- b. If such alternative power source as described in paragraph a. above is not in existence and no date for its implementation appears in Part I, take such precautions as are necessary to maintain and operate the facility under its control in a manner that will minimize upsets and insure stable operation until power is restored.

9. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal act and the Wyoming Environmental Quality Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. The permittee shall give the administrator of the Water Quality Division advance notice of any planned changes at the permitted facility or of any activity which may result in permit noncompliance.

10. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

11. Signatory Requirements

All applications, reports or information submitted to the administrator of the Water Quality Division shall be signed and certified.

- a. All permit applications shall be signed as follows:
  - (1) For a corporation: by a responsible corporate officer;
  - (2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively;
  - (3) For a municipality, state, federal or other public agency: by either a principal executive officer or ranking elected official.
- b. All reports required by the permit and other information requested by the administrator of the Water Quality Division shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - (1) The authorization is made in writing by a person described above and submitted to the administrator of the Water Quality Division; and
  - (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility or an individual or position having overall responsibility for environmental matters for the company. A duly authorized representative may thus be either a named individual or any individual occupying a named position.
- c. If an authorization under paragraph II.A.11.b. is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph II.A.11.b must be submitted to the administrator of the Water Quality Division prior to or together with any reports, information or applications to be signed by an authorized representative.
- d. Any person signing a document under this section shall make the following certification:

"I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the

system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

B. RESPONSIBILITIES

1. Inspection and Entry

If requested, the permittee shall provide written certification from the surface landowner(s), if different than the permittee, that the administrator or the administrator's authorized agent has access to all physical locations associated with this permit including well heads, discharge points, reservoirs, monitoring locations, and any waters of the state.

The permittee shall allow the administrator of the Water Quality Division or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices or operations regulated or required under this permit; and
- d. Sample or monitor, at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the federal act, any substances or parameters at any location.

2. Transfer of Ownership or Control

In the event of any change in control or ownership of facilities from which the authorized discharges emanate, the permittee shall notify the succeeding owner or controller of the existence of this permit by letter, a copy of which shall be forwarded to the regional administrator of the Environmental Protection Agency and the administrator of the Water Quality Division. The administrator of the Water Quality Division shall then provide written notification to the new owner or controller of the date in which they assume legal responsibility of the permit. The permit may be modified or revoked and reissued to change the name of the permittee and incorporate such other requirements as described in the federal act.

3. Availability of Reports

Except for data determined to be confidential under Section 308 of the federal act, all reports prepared in accordance with the terms of this permit shall be available for public

inspection at the offices of the Wyoming Department of Environmental Quality and the regional administrator of the Environmental Protection Agency. As required by the federal act, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the federal act.

4. Toxic Pollutants

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the federal act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Changes in Discharge of Toxic Substances

Notification shall be provided to the administrator of the Water Quality Division as soon as the permittee knows of, or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - (1) One hundred micrograms per liter (100 µg/l);
  - (2) Two hundred micrograms per liter (200 µg/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
  - (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21 (g) (7); or
  - (4) The level established by the director of the Environmental Protection Agency in accordance with 40 CFR 122.44 (f).
  
- b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - (1) Five hundred micrograms per liter (500 µg/l);
  - (2) One milligram per liter (1 mg/l) for antimony;
  - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21 (g) (7); or

- (4) The level established by the director of the Environmental Protection Agency in accordance with 40 CFR 122.44 (f).

6. Civil and Criminal Liability

Nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. As long as the conditions related to the provisions of "Bypass of Treatment Facilities" (Part II.A.5), "Upset Conditions" (Part II.A.6), and "Power Failures" (Part II.A.8) are satisfied then they shall not be considered as noncompliance.

7. Need to Halt or Reduce Activity not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

8. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under Section 311 of the federal act.

9. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state or federal law or regulation. In addition, issuance of this permit does not substitute for any other permits required under the Clean Water Act or any other federal, state, or local law.

10. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights nor any infringement of federal, state or local laws or regulations.

11. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The application should be submitted at least 180 days before the expiration date of this permit.

12. Duty to Provide Information

The permittee shall furnish to the administrator of the Water Quality Division, within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing or terminating this permit or

to determine compliance with this permit. The permittee shall also furnish to the administrator, upon request, copies of records required by this permit to be kept.

13. Other Information

When the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or any report to the administrator of the Water Quality Division, it shall promptly submit such facts or information.

14. Permit Action

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

15. Permit Fees

Once this permit has been issued, the permittee will be assessed a \$100.00 per-year permit fee by the Water Quality Division. The fee year runs from January 1st through December 31st. This permit fee will continue to be assessed for as long as the permit is active, regardless of whether discharge actually occurs. This fee is not pro-rated. If the permit is active during any portion of the fee year, the full fee will be billed to the permittee for that fee year. In the event that this permit is transferred from one permittee to another, each party will be billed the full permit fee for the fee year in which the permit transfer was finalized. See the Wyoming Environmental Quality Act §35-11-312 for further information.

PART III

A. OTHER REQUIREMENTS

1. Percentage Removal Requirements

The arithmetic mean of the Total BOD and the Total Suspended Solids concentrations for effluent samples collected in a period of 30 consecutive days shall not exceed 15 percent of the arithmetic mean of the concentrations for influent samples collected at approximately the same times during the same period (85 percent removal). This is in addition to the concentration limitations on Total BOD and Total Suspended Solids. In the case of stabilization pond treatment systems, this section does not apply to the parameter Total Suspended Solids.

2. Violations Resulting from Overloading

Should there be a violation of any conditions of this permit, the Wyoming Department of Environmental Quality has the authority under Sections 35-11-901 and 35-11-902 of the Wyoming Environmental Quality Act to proceed in a court of competent jurisdiction to restrict or prohibit further connections to the treatment system covered by this permit by any sources not utilizing the system prior to the finding that such a violation occurred.

3. Discharge Duration

If the rate of discharge is controlled, that rate and duration of discharge shall be reported.

4. Flow Measurement

At the request of the Administrator of the Water Quality Division, the permittee must be able to show proof of the accuracy of any flow measuring device used in obtaining data submitted in the monitoring report. The flow measuring device must indicate values of within plus or minus ten (10) percent of the actual flow being measured.

5. Sewer Overflow Located Prior to Waste Treatment Facility

Overflow structures shall be maintained and operated in such a manner that no discharge shall occur except to prevent health hazards, severe property damage or loss of treatment capacity.

Such overflows shall satisfy Wyoming water quality standards and/or any appropriate federal or state effluent limitations. Following documentation of specific water quality standard or effluent standard violations resulting from such overflows, specific numerical effluent limitations, or the requirement for elimination of the overflow structures, may be included upon reissuance or revision of this permit.

6. Compliance with Construction Grant

In the case of publicly owned treatment works, the permittee shall comply with those terms of any construction grant implementing the provisions of Section 201 (b) through (g) of the Clean Water Act.

7. 208 (b) Plans

This permit may be modified, suspended or revoked to comply with the provisions of any 208 (b) plan certified by the Governor of the State of Wyoming.

8. Reopener Provision

This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations (and compliance schedule, if necessary) or other appropriate requirements if one or more of the following events occurs:

- a. The state water quality standards of the receiving water(s) to which the permittee discharges are modified in such a manner as to require different effluent limits than contained in this permit;
- b. A total maximum daily load (TMDL) and/or watershed management plan is developed and approved by the state and/or the Environmental Protection Agency which specifies a wasteload allocation for incorporation in this permit;
- c. A revision to the current water quality management plan is approved and adopted which calls for different effluent limitations than contained in this permit;
- d. Downstream impairment is observed and the permitted facility is contributing to the impairment;
- e. The limits established by the permit no longer attain and/or maintain applicable water quality standards;
- f. The permit does not control or limit a pollutant that has the potential to cause or contribute to a violation of a state water quality standard.
- g. If new applicable effluent guidelines and/or standards have been promulgated and the standards are more stringent than the effluent limits established by the permit.
- h. In order to protect water quality standards in neighboring states, effluent limits may be incorporated into this permit or existing limits may be modified to ensure that the appropriate criteria, water quality standards and assimilative capacity are attained.

9. Permit Modification

After notice and opportunity for a hearing, this permit may be modified, suspended or revoked in whole or in part during its term for cause including, but not limited to, the following:

- a. Violation of any terms or conditions of this permit;
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts;
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. If necessary to comply with any applicable effluent standard or limitation issued or approved under Sections 301 (b) (2) (C) and (D), 304 (b) (2) and 307 (a) (2) of the federal act, if the effluent standard or limitation so issued or approved:
  - (1) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
  - (2) Controls any pollutant not limited in the permit.

10. Toxicity Limitation - Reopener Provision

This permit may be reopened and modified (following proper administrative procedures) to include a new compliance date, additional or modified numerical limitations, a new or different compliance schedule, a change in the whole effluent protocol or any other conditions related to the control of toxicants if one or more of the following events occur:

- a. Toxicity was detected late in the life of the permit near or past the deadline for compliance;
- b. The toxicity reduction evaluation (TRE) results indicate that compliance with the toxic limits will require an implementation schedule past the date for compliance and the permit issuing authority agrees with the conclusion;
- c. The TRE results indicate that the toxicant(s) represent pollutant(s) that may be controlled with specific numerical limits and the permit issuing authority agrees that numerical controls are the most appropriate course of action;
- d. Following the implementation of numerical controls on toxicants, the permit issuing authority agrees that a modified whole effluent protocol is necessary to compensate for those toxicants that are controlled numerically;
- e. The TRE reveals other unique conditions or characteristics which, in the opinion of the permit issuing authority, justify the incorporation of unanticipated special conditions in the permit.

11. Severability

The provisions of this permit are severable and if, any provision of this permit or the application of any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances and the remainder of this permit, shall not be affected thereby.

12. Penalties for Falsification of Reports

The federal act provides that any person who knowingly makes any false statement, representation or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation or by imprisonment for not more than two years per violation or both.

B. INDUSTRIAL WASTES

1. The Permittee has the responsibility to protect the Publicly-Owned Treatment Works (POTW) from pollutants which would inhibit, interfere, or otherwise be incompatible with operation of the treatment works including interference with the use or disposal of municipal sludge.
  2. Pretreatment Standards (40 CFR Section 403.5) developed pursuant to Section 307 of the Federal Clean Water Act (the Act) require that the Permittee shall not allow, under any circumstances, the introduction of the following pollutants to the POTW from any source of nondomestic discharge:
    - a. Any other pollutant which may cause Pass Through or Interference;
    - b. Pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, wastestreams with a closed cup flashpoint of less than sixty (60) degrees Centigrade (140 degrees Fahrenheit) using the test methods specified in 40 CFR Section 261.21;
    - c. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with a pH of lower than 5.0 s.u., unless the treatment facilities are specifically designed to accommodate such discharges;
    - d. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, or other interference with the operation of the POTW;
    - e. Any pollutant, including oxygen demanding pollutants (e.g., BOD), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with any treatment process at the POTW;
    - f. Heat in amounts which will inhibit biological activity in the POTW resulting in Interference, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds forty (40) degrees Centigrade (104 degrees Fahrenheit) unless the Approval Authority, upon request of the POTW, approves alternate temperature limits;
    - g. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through at the POTW;
    - h. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;

- i. Any trucked or hauled pollutants, except at discharge points designated by the POTW; and
  - j. Any specific pollutant which exceeds a local limitation established by the Permittee in accordance with the requirements of 40 CFR Section 403.5(c) and (d).
3. EPA shall be the Approval Authority and the mailing address for all reporting and notifications to the Approval Authority shall be Policy, Enforcement Management and Environmental Justice Program (ENF-PJ), Attention: NPDES Enforcement, U.S. EPA Region 8, 1595 Wynkoop Street, Denver, CO 80202-1129. Should the State be delegated authority to implement and enforce the Pretreatment Program in the future, the Permittee shall be notified of the delegation and the state shall become the Approval Authority.
  4. In addition to the general limitations expressed above, more specific Pretreatment Standards have been and will be promulgated for specific industrial categories under Section 307 of the Act (40 CFR Part 405 et. seq.).
  5. The Permittee must notify the state and the Approval Authority, of any new introductions by new or existing industrial users or any substantial change in pollutants from any industrial user within sixty (60) days following the introduction or change. Such notice must identify:
    - a. Any new introduction of pollutants into the POTW from an industrial user which would be subject to Sections 301, 306, and 307 of the Act if it were directly discharging those pollutants; or
    - b. Any substantial change in the volume or character of pollutants being introduced into the POTW by any industrial user;
    - c. For the purposes of this section, adequate notice shall include information on:
      - (1) The identity of the industrial user;
      - (2) The nature and concentration of pollutants in the discharge and the average and maximum flow of the discharge to be introduced into the POTW; and
      - (3) Any anticipated impact of the change on the quantity or quality of effluent to be discharged from or biosolids produced at such POTW.
    - d. For the purposes of this section, an industrial user shall include:
      - (1) Any discharger subject to Categorical Pretreatment Standards under Section 307 of the Act and 40 CFR chapter I, subchapter N;
      - (2) Any discharger which has a process wastewater flow of 25,000 gallons or more per day;
      - (3) Any discharger contributing five percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant;

- (4) Any discharger who is designated by the Approval Authority as having a reasonable potential for adversely affecting the POTW's operation or for violating any Pretreatment Standards or requirements;
6. The Permittee shall sample and analyze the effluent for the following pollutants:

Total Arsenic	Total Nickel
Total Cadmium	Total Selenium
Total Chromium	Total Silver
Total Copper	Total Zinc
Total Lead	Total Cyanide
Total Mercury	Total Phenols
Total Molybdenum	

The sampling shall commence within thirty (30) days of the effective date of this permit and continue at a frequency of once per year.

Sampling and analytical procedures shall be in accordance with guidelines established in 40 CFR Part 136. Where sampling methods are not specified the effluent samples collected shall be composite samples consisting of at least twelve (12) aliquots collected at approximately equal intervals over a representative 24 hour period and composited according to flow. Where a flow proportioned composite sample is not practical, the Permittee shall collect at least three (3) grab samples, taken at equal intervals over a representative 24 hour period. Lagoon treatment systems may collect a single effluent grab sample.

The results of all analyses shall be attached to, and reported along with the Discharge Monitoring Report (DMR) submitted for the end of that reporting period.

7. At such time as a specific pretreatment limitation becomes applicable to an industrial user of the Permittee, the state and/or Approval Authority may, as appropriate:
- a. Amend the Permittee's discharge permit to specify the additional pollutant(s) and corresponding effluent limitation(s) consistent with the applicable Pretreatment Standards;
  - b. Require the Permittee to specify, by ordinance, order, or other enforceable means, the type of pollutant(s) and the maximum amount which may be discharged to the Permittee's POTW for treatment. Such requirement shall be imposed in a manner consistent with the POTW program development requirements of the General Pretreatment Regulations at 40 CFR Part 403; and/or,
  - c. Require the Permittee to monitor its discharge for any pollutant which may likely be discharged from the Permittee's POTW, should the industrial user fail to properly pretreat its waste.
8. The state and the Approval Authority retains, at all times, the right to take legal action against any source of nondomestic discharge, whether directly or indirectly controlled by

the Permittee, for violations of a permit, order or similar enforceable mechanism issued by the Permittee, violations of any Pretreatment Standard or requirement, or for failure to discharge at an acceptable level under national standards issued by EPA under 40 CFR, chapter I, subchapter N. In those cases where a permit violation has occurred because of the failure of the Permittee to properly develop and enforce Pretreatment Standards and requirements as necessary to protect the POTW, the state and/or Approval Authority shall hold the Permittee and/or industrial user responsible and may take legal action against the Permittee as well as the industrial user(s) contributing to the permit violation.

83437-doc  
12/01