

**Wyoming Department of Environmental Quality
Water Quality Division
WYPDES (Wyoming Pollutant Discharge Elimination System) Program**

STATEMENT OF BASIS

RENEWAL

APPLICANT NAME: Chevron Environmental Management Company

MAILING ADDRESS: 6001 Bollinger Canyon, C2052
San Ramon, CA 94583

FACILITY LOCATION: Texaco Casper Plant, which is located in SWSW Section 29, Township 34N, Range 78W, Natrona County. The wastewater will discharge to a series of seven unnamed intermittent lakes within an unnamed closed basin (3A), North Platte River drainage

PERMIT NUMBER: WY0036412

This permit has been renewed in accordance with current WYPDES permitting requirements. All permit effluent limits and monitoring requirements have been updated in accordance with current WDEQ regulations and policy. Specific changes to the permit include the following:

1. *Revised language regarding access to the facility is in Part II.B.1 of the permit.*
2. *A limit on oil and grease is included. In the event that an oil sheen or floating oil is observed in the discharge, a grab sample shall be immediately taken, analyzed and reported. The sample shall not exceed 10 mg/L.*
3. *The facility was non-discharging at the time of permit application, so the required up front water analyses were not included. This permit includes an initial monitoring report requirement involving the constituents in the permit application. The constituents are as follows:*

<i>Biochemical Oxygen Demand (BOD5)</i>	<i>Ammonia (as N)</i>
<i>Chemical Oxygen Demand</i>	<i>Temperature</i>
<i>Total Organic Carbon</i>	<i>pH</i>
<i>Total Suspended Solids</i>	<i>Color of Discharge</i>

Background: The Former Texaco Refinery (Site) is located adjacent to Evansville, Wyoming in Natrona County. The Site is currently in the Wyoming Voluntary Remediation Program and Chevron Environmental Management Company (CEMC) has been working with WDEQ on remedy selection and implementation. As part of the remedy implementation process, CEMC has agreed to pump groundwater from extraction wells located on the South Property of the Site. The extracted groundwater passes through an oil/water separator, an air stripper, and is then routed to a basin to allow for additional aeration and settling, serving as a final polishing step. After treatment, the water is piped to a lined inlet pond located on the North Property. From the inlet pond, the treated water gravity drains through a pipe to a larger pond known as Pond 1. When the treated water pumping rate exceeds the Pond 1 evaporation rates, Pond 1 water flows through a narrow, open channel to another pond known as Pond 2. Pond 2 is

part of a series of intermittent evaporation ponds located within a closed basin on the North Property. There is no surface discharge from Pond 2. Outfall 001 is between Pond 1 and Pond 2.

Effluent Limits: Permit limits include 50 µg/L benzene, 750 µg/L total BTEX, 10 mg/L total petroleum hydrocarbons, 7500 µS/cm specific conductance. These limits are based upon Chapter 1, Wyoming Water Quality Rules and Regulations and recommendations provided by the EPA for discharges related to "Cleanup of Gasoline Released from Underground Storage Tanks". Also, the 7500 µS/cm limit on specific conductance is based on Chapter 2, Appendix H, for protection of livestock. In addition, a limit on oil and grease is included. In the event that an oil sheen or floating oil is observed in the discharge, a grab sample shall be immediately taken, analyzed and reported. The sample shall not exceed 10 mg/L

The effluent limit for total selenium is established at 15 µg/L. Based on risk assessment work performed by the permittee in cooperation with WDEQ/SHWD and U.S. Fish and Wildlife Service, it has been determined that selenium levels in the permitted effluent less than or equal to 15 µg/L pose no significant risk to the resident aquatic life and terrestrial species. Therefore, a discharge limit of 15 µg/L for total selenium is established in this permit. The permit also limits pH to a minimum of 6.5 and a maximum of 9.0 standard units, based on Chapter 1

The permit establishes effluent limits for the end of pipe, which are protective of the designated uses for class 3A waters as defined in *Chapter 1 of Wyoming Water Quality Rules and Regulations*. These include aquatic life other than fish, recreation, agriculture, wildlife, industry and scenic value. Water quality based effluent limits for this permit are based on standards which are intended to protect for the above listed designated uses and reflect the application of "tier 1" antidegradation protection. Tier 1 antidegradation protection is the basic level of protection that applies to all waters of the state, as described in the Wyoming Surface Water Quality Standards "Implementation Policies for Antidegradation."

Antidegradation, impairment review: The discharge of wastewater and the effluent limits established in this permit ensure that the levels of water quality maintain and protect the designated uses of the receiving waters. An antidegradation review verifies that the permit conditions, including the effluent limitations established, provide a level of protection to the receiving water consistent with the antidegradation provisions of Wyoming surface water quality standards. An evaluation has been completed and the North Platte River (class 2AB) is impaired for selenium in this area of the state. However, the discharge does not enter the North Platte River.

Self-monitoring of effluent quality and quantity is required on a regular basis with reporting of results quarterly. The permit is scheduled to expire on August 31, 2023.

Roland Peterson
Water Quality Division
Department of Environmental Quality
Drafted: March 8, 2018

AUTHORIZATION TO DISCHARGE UNDER THE
WYOMING POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Water Pollution Control Act, (hereinafter referred to as "the Act"), and the Wyoming Environmental Quality Act,

Chevron Environmental Management Company

is authorized to discharge from the wastewater treatment facilities serving the

Texaco Casper Plant

located in

SWSW Section 29, Township 34N, Range 78W, Natrona County

to receiving waters named

a series of seven unnamed intermittent lakes within an unnamed closed basin (3A), North Platte River Basin

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II and III hereof.

This permit shall become effective on September 1, 2018.

This permit and the authorization to discharge shall expire August 31, 2023 at midnight.

Kevin Frederick, Administrator
Water Quality Division

Todd Parfitt, Director
Department of Environmental Quality

Date of Issuance: _____

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. Effective September 1, 2018 and lasting through August 31, 2023 the quality of effluent discharged by the permittee shall, at a minimum, meet the limitations set forth below. The permittee is authorized to discharge from outfall serial number(s) 001.

Such discharges shall be limited and monitored by the permittee as specified below:

Parameter	Monthly Average	Weekly Average	Daily Maximum
Benzene, µg/L	N/A	N/A	50
pH, su	N/A	N/A	6.5-9.0*
Specific Conductance, µS/cm	N/A	N/A	7500
Total BTEX, µg/L	N/A	N/A	750
Total Petroleum Hydrocarbons, mg/L	N/A	N/A	10
Total Selenium, µg/L	N/A	N/A	15
Oil and Grease, mg/L	N/A	N/A	10*

*In the event that an oil sheen or floating oil is observed in the discharge, a grab sample shall be immediately taken, analyzed and reported. The sample shall not exceed 10 mg/L.

The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units in any single grab sample.

There shall be no discharge of floating solids or foam in other than trace amounts. Nor shall the discharge have a visible sheen or cause formation of a visible sheen or visible deposits on the bottom or shoreline of the receiving water.

All waters shall be discharged in a manner to prevent erosion, scouring, or damage to stream banks, stream beds, ditches, or other waters of the state at the point of discharge. Discharges shall not occur in such a manner that will result in violations of Water Quality Rules and Regulations, Chapter 1, Section 15. In addition, there shall be no deposition of substances in quantities that could result in significant aesthetic degradation, or degradation of habitat for aquatic life, plant life or wildlife; or which could adversely affect public water supplies or those intended for agricultural or industrial use.

2. Discharges shall be monitored by the permittee as specified below:

a. Routine monitoring End of Pipe—for outfall(s) 001

<u>Monitoring Requirements</u>		
<u>Effluent Characteristic</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Benzene, µg/L	Monthly	Grab
Flow - MGD	Weekly	Instantaneous or Continuous
pH, su (standard units)	Monthly	Grab
Specific Conductance, µS/cm	Monthly	Grab
Total BTEX, µg/L	Monthly	Grab
Total Petroleum Hydrocarbons, mg/L	Monthly	Grab
Total Selenium, µg/L	Monthly	Grab
Oil and Grease	Continuous	Visible sheen*

*Samples shall not be collected unless a visual sheen is detected. The sample must then comply with the limit listed above.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the outfall from the final treatment unit and prior to admixture with diluent water or the receiving stream.

3. One-Time Initial Monitoring

Discharges shall be monitored by the permittee specified as follows. Within 60 days of commencement of discharge, a sample shall be collected from each outfall and analyzed for the constituents specified below, at the required detection limits. Within 90 days of commencement of discharge, a summary report on the produced water must be submitted to the Wyoming Department of Environmental Quality at the address listed below. This summary report must include the results and detection limits for each of the constituents. After receiving the monitoring results for the initial discharge, the effluent limits and monitoring requirements established in this permit may be modified. Constituents are as follows:

- | | |
|----------------------------------|--------------------|
| Biochemical Oxygen Demand (BOD5) | Ammonia (as N) |
| Chemical Oxygen Demand | Temperature |
| Total Organic Carbon | pH |
| Total Suspended Solids | Color of Discharge |

B. MONITORING AND REPORTING

1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other wastestream, body of water, or substance. Monitoring points shall not be changed without notification to and approval by, the permit issuing authority.

2. Reporting

Effluent monitoring results obtained during the previous three month(s) shall be summarized and reported on a Discharge Monitoring Report Form. If the permit requires whole effluent toxicity (WET) (biomonitoring) testing, WET test results must be reported on the most recent version of EPA Region 8 Guidance for Whole Effluent Reporting. Legible copies of these, and all other reports required herein, shall be signed and certified in accordance with the Signatory Requirements (see Part II.A.11.), and submitted to the state water pollution control agency at the following address. The reports must be received by the agency no later than the 28th day of the month following the completed reporting period. The first report is due October 28, 2018.

Wyoming Department of Environmental Quality
Water Quality Division
200 West 17th Street
Cheyenne, WY 82002
Telephone: (307) 777-7781

If no discharge occurs during the reporting period, "no discharge" shall be reported. If discharge is intermittent during the reporting period, sampling shall be done while the facility is discharging.

3. Definitions

Concentration Values

- a. Daily Maximum (mg/L) - The highest single reading from any grab or composite sample collected during the reporting period.
- b. Monthly Average (mg/L) - The arithmetic mean (geometric mean in the case of fecal coliform and E. coli) of all composite and/or grab samples collected during a calendar month.
- c. Weekly Average (mg/L) - The arithmetic mean (geometric mean in the case of fecal coliform and E. coli) of all composite and/or grab samples collected during any week. A week begins at 12:01 a.m. Sunday morning and ends at 12:00 midnight Saturday evening.

Quantity Values

- d. Daily Maximum - The highest single daily quantity reading (see Calculations below) recorded during the reporting period.
- e. Monthly Average - The arithmetic mean (geometric mean in the case of fecal coliform and E. coli bacteria) of all the daily quantity readings (see Calculations below) recorded during a calendar month.

- f. Weekly Average - The arithmetic mean (geometric mean in the case of fecal coliform and E. coli bacteria) of all the daily quantity readings (see Calculations below) recorded during a week. A week begins at 12:01 a.m. Sunday morning and ends at 12:00 midnight Saturday evening.

Flow Values

- g. Daily Flow - The flow volume recorded on any single day. The daily flow volume may be determined by using an instantaneous reading (if authorized by this permit) or a continuous recorder.
- h. Daily Maximum Flow - The highest single daily flow reading recorded during a reporting period.
- i. Monthly Average Flow - The arithmetic mean of all daily flow values recorded during a calendar month.
- j. Weekly Average Flow - The arithmetic mean of all daily flow values recorded during a week. A week begins at 12:01 am on Sunday morning and ends at 12:00 midnight Saturday evening.

Calculations

- k. Daily Quantity (kg/day) - The quantity, in kilograms per day, of pollutant discharged on a single day. The Daily quantity shall be calculated by multiplying the composite or grab sample concentration value for that day in milligrams/liter (mg/L) times the flow volume (in millions of gallons per day - MGD) for that day times 3.78. If a flow volume reading for the day the sample is collected is not available, the average flow volume reading for the entire reporting period shall be used.
- l. Daily Quantity (#/day) - The quantity, in number per day, of bacteria or other pollutants discharged on a single day. The number per day shall be calculated by multiplying the composite or grab sample result for that day, in number per 100 milliliters (#/100 ml), times the flow volume (in millions of gallons per day - MGD) times 3.78×10^7 . If a flow volume reading for the day the sample is collected is not available, the average flow volume reading for the entire reporting period shall be used.
- m. Geometric Mean - Calculated in accordance with the procedure described in the most recent edition of "Standard Methods for the Examination of Water and Wastewater".

Miscellaneous

- n. A "composite" sample, for monitoring requirements, is defined as a minimum of four (4) grab samples collected at equally spaced two (2) hour intervals and proportioned according to flow.
- o. An "instantaneous" measurement for monitoring requirements is defined as a single reading, measurement, or observation.

- p. "MGD", for monitoring requirements, is defined as million gallons per day.
- q. "Net" value, if noted under Effluent Characteristics, is calculated on the basis of the net increase of the individual parameter over the quantity of that same parameter present in the intake water measured prior to any contamination or use in the process of this facility. Any contaminants contained in any intake water obtained from underground wells shall not be adjusted for as described above and, therefore, shall be considered as process input to the final effluent. Limitations in which "net" is not noted are calculated on the basis of gross measurements of each parameter in the discharge, irrespective of the quantity of those parameters in the intake waters.
- r. A "pollutant" is any substance or substances that, if allowed to enter surface waters of the state, causes or threatens to cause pollution as defined in the Wyoming Environmental Quality Act, Section 35-11-103.

4. Test Procedures

Test procedures for the analysis of pollutants, collection of samples, sample containers, sample preservation, and holding times, shall conform to regulations published pursuant to 40 CFR, Part 136, unless other test procedures have been specified in this permit.

5. Recording of Results

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- a. The exact place, date and time of sampling;
- b. The dates and times the analyses were performed;
- c. The person(s) who performed the analyses and collected the samples;
- d. The analytical techniques or methods used; and
- e. The results of all required analyses including the bench sheets, instrument readouts, computer disks or tapes, etc., used to determine the results.

6. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified above, the results of such monitoring shall be included in the calculation and reporting of the values required in the Discharge Monitoring Report Form. Such increased frequency shall also be indicated.

7. Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring

instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the administrator at any time. Data collected on site, copies of Discharge Monitoring Reports and a copy of this WYPDES permit must be maintained on site during the duration of activity at the permitted location.

8. Penalties for Tampering

The Act provides that any person who falsifies, tampers with or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or both.

9. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any Compliance Schedule of this permit shall be submitted no later than 14 days following each schedule date.

10. Location of Discharge Points

TABLE 1
 OUTFALLS
 WY0036412, Texaco Casper Plant
Table 1: WY0036412 Texaco Casper Plant

Out-fall	Qtr/Qtr	SEC-TION	TWP (N)	RNG (W)	LATITUDE	LONGITUDE	Drainage / Description
001*	SWSW	29	34	78	42.88288	-106.23580	A series of seven unnamed intermittent lakes (3A) within an unnamed closed basin, North Platte River drainage

*Outfall location was DEQ-verified on 2/19/2014.

PART II

A. MANAGEMENT REQUIREMENTS

1. Changes

The permittee shall give notice to the administrator of the Water Quality Division as soon as possible of any physical alterations or additions to the permitted facility. Notice is required when:

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as determined in 40 CFR 122.29 (b); or
- b. The alteration or addition could change the nature or increase the quantity of pollutants discharged.

2. Noncompliance Notification

- a. The permittee shall give advance notice of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- b. The permittee shall report any noncompliance which may endanger health or the environment as soon as possible, but no later than 24 hours from the time the permittee first became aware of the circumstances. The report shall be made to the Water Quality Division, Wyoming Department of Environmental Quality at (307) 777-7781.
- c. For any incidence of noncompliance, including noncompliance related to non-toxic pollutants or non-hazardous substances, a written submission shall be provided within five (5) days of the time that the permittee becomes aware of the noncompliance circumstance.

The written submission shall contain:

- (1) A description of the noncompliance and its cause;
 - (2) The period of noncompliance, including exact dates and times;
 - (3) The estimated time noncompliance is expected to continue if it has not been corrected; and
 - (4) Steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance.
- d. The following occurrences of unanticipated noncompliance shall be reported by telephone to the Water Quality Division, Watershed Management Section, WYPDES Program (307) 777-7781 as soon as possible, but no later than 24 hours from the time the permittee first became aware of the circumstances.

- (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
 - (2) Any upset which exceeds any effluent limitation in the permit; or
 - (3) Violation of a maximum daily discharge limitation for any toxic pollutants or hazardous substances, or any pollutants specifically identified as the method to control a toxic pollutant or hazardous substance listed in the permit.
- e. The administrator of the Water Quality Division may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Water Quality Division, WYPDES Program (307) 777-7781.
- f. Reports shall be submitted to the Wyoming Department of Environmental Quality at the address in Part I under Reporting and to the Planning and Targeting Program, 8ENF-PT, Office of Enforcement, Compliance, and Environmental Justice, U.S. EPA Region 8, 1595 Wynkoop Street, Denver, CO 80202-1129.
- g. The permittee shall report all instances of noncompliance that have not been specifically addressed in any part of this permit at the time the monitoring reports are due.

3. Facilities Operation

The permittee shall, at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of the permit. However, the permittee shall operate, as a minimum, one complete set of each main line unit treatment process whether or not this process is needed to achieve permit effluent compliance.

4. Adverse Impact

The permittee shall take all reasonable steps to minimize any adverse impact to waters of the state resulting from noncompliance with any effluent limitations specified in this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

5. Bypass of Treatment Facilities

- a. Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
- b. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it is for essential maintenance to assure

efficient operation. These bypasses are not subject to the provisions of paragraphs c. and d. of this section. Return of removed substances to the discharge stream shall not be considered a bypass under the provisions of this paragraph.

c. Notice:

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice at least 60 days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required under Part II.A.2.

d. Prohibition of bypass.

- (1) Bypass is prohibited and the administrator of the Water Quality Division may take enforcement action against a permittee for a bypass, unless:
 - (a) The bypass was unavoidable to prevent loss of life, personal injury or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (c) The permittee submitted notices as required under paragraph c. of this section.

e. The administrator of the Water Quality Division may approve an anticipated bypass, after considering its adverse effects, if the administrator determines that it will meet the three conditions listed above in paragraph d. (1) of this section.

6. Upset Conditions

- a. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improper designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- b. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of paragraph c. of this section are met.

- c. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that:
- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required under Part II.A.2; and
 - (4) The permittee complied with any remedial measures required under Part II.A.4.
- d. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

7. Removed Substances

Solids, sludges, filter backwash or other pollutants removed in the course of treatment or control of wastewaters or intake waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering waters of the state.

8. Power Failures

In order to maintain compliance with the effluent limitations and prohibitions of this permit, the permittee shall either:

- a. In accordance with a schedule of compliance contained in Part I, provide an alternative power source sufficient to operate the wastewater control facilities; or
- b. If such alternative power source as described in paragraph a. above is not in existence and no date for its implementation appears in Part I, take such precautions as are necessary to maintain and operate the facility under its control in a manner that will minimize upsets and insure stable operation until power is restored.

9. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal act and the Wyoming Environmental Quality Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. The permittee shall give the administrator of the Water Quality Division advance notice of any planned changes at the permitted facility or of any activity which may result in permit noncompliance.

10. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

11. Signatory Requirements

All applications, reports or information submitted to the administrator of the Water Quality Division shall be signed and certified.

a. All permit applications shall be signed as follows:

- (1) For a corporation: by a responsible corporate officer;
- (2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively;
- (3) For a municipality, state, federal or other public agency: by either a principal executive officer or ranking elected official.

b. All reports required by the permit and other information requested by the administrator of the Water Quality Division shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described above and submitted to the administrator of the Water Quality Division; and
- (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility or an individual or position having overall responsibility for environmental matters for the company. A duly authorized representative may thus be either a named individual or any individual occupying a named position.

c. If an authorization under paragraph II.A.11.b. is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph II.A.11.b must be submitted to the administrator of the Water Quality Division prior to or together with any reports, information or applications to be signed by an authorized representative.

d. Any person signing a document under this section shall make the following certification:

"I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the

system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

B. RESPONSIBILITIES

1. A. Providing Access

The permittee shall allow Department of Environmental Quality personnel and their invitees to enter the premises where the facility is located, or where records are kept under the conditions of this permit, and collect resource data as defined by Wyoming Statute § 6-3-414, inspect and photograph the facility, collect samples for analysis, review records, and perform any other function authorized by law or regulation. The permittee shall secure and maintain such access for the duration of the permit.

If the facility is located on property not owned by the permittee, the permittee shall also secure and maintain from the landowner upon whose property the facility is located permission for Department of Environmental Quality personnel and their invitees to enter the premises where a regulated facility is located, or where records are kept under the conditions of this permit, and collect resource data as defined by Wyoming Statute § 6-3-414, inspect and photograph the facility, collect samples for analysis, review records, and perform any other function authorized by law. The permittee shall secure and maintain such access for the duration of the permit.

If the facility cannot be directly accessed using public roads, the permittee shall also secure and maintain permission for Department of Environmental Quality personnel and their invitees to enter and cross all properties necessary to access the facility. The permittee shall secure and maintain such access for the duration of the permit.

B. Access Records

The permittee shall maintain in its records documentation that demonstrates that the permittee has secured permission for Department of Environmental Quality personnel and their invitees to access the permitted facility, including (i) permission to access the land where the facility is located, (ii) permission to collect resource data as defined by Wyoming Statute § 6-3-414, and (iii) permission to enter and cross all properties necessary to access the facility if the facility cannot be directly accessed from a public road. The permittee shall also maintain in its records a current map of the access route(s) to the facility and contact information for the owners or agents of all properties that must be crossed to access the facility. The permittee shall ensure that the documentation, map, and contact information are current at all times. The permittee shall provide the documentation, map, and contact information to Department of Environmental Quality personnel upon request. Upon termination of the permit, the permittee shall maintain such records for a period of three (3) years.

2. Transfer of Ownership or Control

In the event of any change in control or ownership of facilities from which the authorized discharges emanate, the permittee shall notify the succeeding owner or controller of the existence of this permit by letter, a copy of which shall be forwarded to the regional administrator of the Environmental Protection Agency and the administrator of the Water Quality Division. The administrator of the Water Quality Division shall then provide written notification to the new owner or controller of the date in which they assume legal responsibility of the permit. The permit may be modified or revoked and reissued to change the name of the permittee and incorporate such other requirements as described in the federal act.

3. Availability of Reports

Except for data determined to be confidential under Section 308 of the federal act, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Wyoming Department of Environmental Quality and the regional administrator of the Environmental Protection Agency. As required by the federal act, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the federal act.

4. Toxic Pollutants

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the federal act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Changes in Discharge of Toxic Substances

Notification shall be provided to the administrator of the Water Quality Division as soon as the permittee knows of, or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (1) One hundred micrograms per liter (100 µg/l);
 - (2) Two hundred micrograms per liter (200 µg/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
 - (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21 (g) (7); or

- (4) The level established by the director of the Environmental Protection Agency in accordance with 40 CFR 122.44 (f).
- b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (1) Five hundred micrograms per liter (500 µg/l);
 - (2) One milligram per liter (1 mg/l) for antimony;
 - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21 (g) (7); or
 - (4) The level established by the director of the Environmental Protection Agency in accordance with 40 CFR 122.44 (f).

6. Civil and Criminal Liability

Nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. As long as the conditions related to the provisions of "Bypass of Treatment Facilities" (Part II.A.5), "Upset Conditions" (Part II.A.6), and "Power Failures" (Part II.A.8) are satisfied then they shall not be considered as noncompliance.

7. Need to Halt or Reduce Activity not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

8. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under Section 311 of the federal act.

9. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state or federal law or regulation. In addition, issuance of this permit does not substitute for any other permits required under the Clean Water Act or any other federal, state, or local law.

10. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property

or any invasion of personal rights nor any infringement of federal, state or local laws or regulations.

11. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The application should be submitted at least 180 days before the expiration date of this permit.

12. Duty to Provide Information

The permittee shall furnish to the administrator of the Water Quality Division, within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the administrator, upon request, copies of records required by this permit to be kept.

13. Other Information

When the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or any report to the administrator of the Water Quality Division, it shall promptly submit such facts or information.

14. Permit Action

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

PART III

A. OTHER REQUIREMENTS

1. Flow Measurement

At the request of the administrator of the Water Quality Division, the permittee must be able to show proof of the accuracy of any flow measuring device used in obtaining data submitted in the monitoring report. The flow measuring device must indicate values of within plus or minus ten (10) percent of the actual flow being measured.

2. 208(b) Plans

This permit may be modified, suspended or revoked to comply with the provisions of any 208(b) plan certified by the Governor of the State of Wyoming.

3. Reopener Provision

This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations (and compliance schedule, if necessary) or other appropriate requirements if one or more of the following events occurs:

- a. The state water quality standards of the receiving water(s) to which the permittee discharges are modified in such a manner as to require different effluent limits than contained in this permit;
- b. A total maximum daily load (TMDL) and/or watershed management plan is developed and approved by the state and/or the Environmental Protection Agency which specifies a wasteload allocation for incorporation in this permit;
- c. A revision to the current water quality management plan is approved and adopted which calls for different effluent limitations than contained in this permit;
- d. Downstream impairment is observed and the permitted facility is contributing to the impairment;
- e. The limits established by the permit no longer attain and/or maintain applicable water quality standards;
- f. The permit does not control or limit a pollutant that has the potential to cause or contribute to a violation of a state water quality standard.
- g. If new applicable effluent guidelines and/or standards have been promulgated and the standards are more stringent than the effluent limits established by the permit.
- h. In order to protect water quality standards in neighboring states, effluent limits may be incorporated into this permit or existing limits may be modified to ensure that the appropriate criteria, water quality standards and assimilative capacity are attained.

4. Permit Modification

After notice and opportunity for a hearing, this permit may be modified, suspended or revoked in whole or in part during its term for cause including, but not limited to, the following:

- a. Violation of any terms or conditions of this permit;
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts;
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. If necessary to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b) (2) (C) and (D), 304 (b) (2) and 307 (a) (2) of the federal act, if the effluent standard or limitation so issued or approved:
 - (1) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) Controls any pollutant not limited in the permit.

5. Toxicity Limitation - Reopener Provision

This permit may be reopened and modified (following proper administrative procedures) to include a new compliance date, additional or modified numerical limitations, a new or different compliance schedule, a change in the whole effluent protocol or any other conditions related to the control of toxicants if one or more of the following events occur:

- a. Toxicity was detected late in the life of the permit near or past the deadline for compliance;
- b. The toxicity reduction evaluation (TRE) results indicate that compliance with the toxic limits will require an implementation schedule past the date for compliance and the permit issuing authority agrees with the conclusion;
- c. The TRE results indicate that the toxicant(s) represent pollutant(s) that may be controlled with specific numerical limits and the permit issuing authority agrees that numerical controls are the most appropriate course of action;
- d. Following the implementation of numerical controls on toxicants, the permit issuing authority agrees that a modified whole effluent protocol is necessary to compensate for those toxicants that are controlled numerically;
- e. The TRE reveals other unique conditions or characteristics which, in the opinion of the permit issuing authority, justify the incorporation of unanticipated special conditions in the permit.

6. Severability

The provisions of this permit are severable and if any provision of this permit, or the application of any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances and the remainder of this permit, shall not be affected thereby.

7. Penalties for Falsification of Reports

The federal act provides that any person who knowingly makes any false statement, representation or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation or by imprisonment for not more than two years per violation or both.