

**SOURCE WATER ASSESSMENT
EXECUTIVE SUMMARY
FOR
BLM-Middle Fork Powder River CG**

June 30, 2004

PROJECT: 424-001

ASSESSMENT COMPLETED BY: TRIHYDRO CORPORATION

1252 Commerce Drive, Laramie, WY 82070



ENGINEERING SOLUTIONS. ADVANCING BUSINESS.

Home Office | 1252 Commerce Drive | Laramie, WY 82070 | phone 307/745.7474 | fax 307/745.7729 | www.trihydro.com

SOURCE WATER ASSESSMENT SUMMARY FOR BLM-Middle Fork Powder River CG

PWS Source Water Assessment Summary

The BLM-Middle Fork Powder River Campground is a transient non-community water supply system located in a remote area of southeast Washakie County. The system serves a transient population of approximately 600 people through one service connection. Facilities include one hand pump well that draws water from the alluvium along the Middle Fork Powder River valley. The water source used by the campground scored medium with respect to the combined integrity and sensitivity summary. The campground scored high with respect to land use susceptibility and low for point source susceptibility.

Delineation Methods

This water system is a non-community system that draws water from porous alluvium. Calculated fixed radius (CFR) methods were implemented to estimate the 2-year and 5-year time of travel radii for the groundwater flow system. The CFR was calculated using well information in the sanitary survey, and aquifer parameters used in the calculation were assumed from those of similar type deposits.

Calculated fixed radius (CFR) is an appropriate method to use when groundwater flow to the well, spring or tunnel can be characterized as porous. This process was implemented for small communities that derive water from deeper, confined aquifers, or for non-community water systems. A factor of safety (FS) of 1.5 was applied to all systems where portions of the data were suspect. At the ground surface, the radius can be used to delineate an area around the well to be used for wellhead protection. The radius is the distance from the well to a point where groundwater (and contaminant) can reach the well over a specified time period. Input data requirements are limited, consisting of the pumping rate, open (screened interval) of the well, porosity of the aquifer, and the selected time of travel (2 years and 5 years).

Groundwater Sources

The BLM-Middle Fork Powder River Campground draws water from the alluvium along the Middle Fork Powder River valley. Recharge to the alluvial aquifer comes from the Middle Fork Powder River and tributaries, and reaches the well through porous media flow. Groundwater flow within the alluvium is generally from north to south. Additional information on this well is included on the attached Well Information Sheet. As shown on the enclosed source water area delineation map, contaminant inventory zones 2 and 3 were delineated using CFR methods. Zone 2 had a calculated radius of 449 feet. Zone 3 had a calculated radius of 710 feet.

Integrity Summary

The Bureau of Land Management Fork Powder River Campground uses one shallow well, approximately 45 feet deep, to supply its water. The well was constructed after 1993 when more stringent construction standards were required by the State of Wyoming. Records indicate that the well was properly sealed to protect from surface infiltration of potential contaminants and flooding around the wellhead. However, the well lacks adequate protection of the vicinity immediately around the wellhead from contaminant sources and the presence of an annular seal is unknown. Therefore, as shown on the Integrity Summary Table; Middlefork Water well received a score of 3.

Water Source Sensitivity Summary

As shown on the Source Sensitivity Summary Table, the well received a sensitivity score of 10. The well received a score of 5 for aquifer sensitivity because it is a shallow well. The well had the also received a score of 5 for chemical sensitivity due to documented chemical detections in the groundwater.

Water System Susceptibility Rating

Susceptibility is defined as the potential for a public water supply to draw contaminated water at concentrations that would pose a threat or concern to human health. In general, the BLM-Middle Fork Powder River Campground scores high for land use susceptibility because much of the land surrounding the water sources is forested. Forested areas were included to evaluate the potential risks of increased runoff and water quality problems following forest fires. The point source contaminant susceptibility rating is low because no point sources of contamination were found within the delineated source zones.

A review of your PWS's routine water analysis results revealed that one or more chemicals that are considered contaminants in drinking water were detected at some time within the last five years. Chemical detections have a large impact on your PWS's sensitivity score because it may indicate that there is a pathway for contaminants to reach the water supply. However, it is likely that these chemicals are present only in small amounts and are not a danger to your health. Some of these chemicals may also occur naturally in water.

For more information about which chemicals were detected, please contact the PWS for a copy of the most recent Consumer Confidence Report or water analysis results. Chemical detections at levels that are a concern to human health are reported on the EPA's website: http://www.epa.gov/enviro/html/sdwis/sdwis_query.html. To see if your PWS has exceeded the federal primary or secondary drinking water standards, just click on the State of Wyoming and then type in the name of your PWS. Consumer Confidence Reports are prepared by the PWS on a yearly basis. The reports should include information about any chemicals found in the water, even those found at very low levels. Please contact Kim Parker at DEQ, 307-777-7781, or WARWS for assistance. You may also contact EPA to find out what contaminants were detected. You may have to fill out a Freedom of Information Act request to obtain the water test results for your PWS. Please call EPA's Safe Drinking Water Hotline at 1-800-426-4791.

**POINT SUSCEPTIBILITY SUMMARY TABLE
FOR BLM-Middle Fork Powder River CG
Point Source Susceptibility Summary**

It may appear from the results of this point source susceptibility summary table that your system has too many PSOCs influencing the final ratings. In some cases, a specific PSOC falls within a specific contaminant inventory zone shared by multiple wells or intakes. When this is the case, that PSOC will be scored for each intake. For example, an underground storage tank may appear within a contaminant inventory zone shared by four different wells. This would cause that single storage tank to be entered into the table four times, or once for each well or intake.

Point Source Type	Low	Medium	High
None Identified	N/A	N/A	N/A

- * Illustrates the number of PSOCs in a particular rating class for all water sources
- * N/A - Not Applicable