

**SOURCE WATER ASSESSMENT
EXECUTIVE SUMMARY
FOR
R Lazy S Ranch**

June 30, 2004

PROJECT: 424-001

ASSESSMENT COMPLETED BY: TRIHYDRO CORPORATION

1252 Commerce Drive, Laramie, WY 82070



ENGINEERING SOLUTIONS. ADVANCING BUSINESS.

Home Office | 1252 Commerce Drive | Laramie, WY 82070 | phone 307/745.7474 | fax 307/745.7729 | www.trihydro.com

SOURCE WATER ASSESSMENT SUMMARY FOR R Lazy S Ranch

PWS Source Water Assessment Summary

R Lazy S Ranch is a non-community groundwater system located in Teton County. The system serves 60 people through 22 service connections. The system is supplied by two wells that draw water from terrace deposits along the Snake River valley. Facilities include a raw water tank, and the interconnecting transmission system. The water sources scored high with respect to the combined integrity and source sensitivity ratings. The ranch scored high with respect to land use susceptibility and point source susceptibility.

Delineation Methods

This water system is a non-community system that draws water from a porous sedimentary formation. Calculated fixed radius (CFR) methods were implemented to estimate the 2-year and 5-year time of travel radii for the groundwater flow system. The CFR was calculated using well information from the SEO database. Aquifer parameters used in the calculation were assumed for those of similar type deposits.

Calculated fixed radius (CFR) is an appropriate method to use when groundwater flow to the well, spring or tunnel can be characterized as porous. This process was implemented for small communities that derive water from deeper, confined aquifers, or for non-community water systems. A factor of safety (FS) of 1.5 was applied to all systems where portions of the data were suspect. At the ground surface, the radius can be used to delineate an area around the well to be used for wellhead protection. The radius is the distance from the well to a point where groundwater (and contaminant) can reach the well over a specified time period. Input data requirements are limited, consisting of the pumping rate, open (screened interval) of the well, porosity of the aquifer, and the selected time of travel (2 years and 5 years).

Groundwater Sources

The R Lazy S Ranch draws water from terrace deposits along the Snake River valley. Recharge to the terrace aquifer comes from the Snake River drainage, and reaches the well through porous media flow. Groundwater flow within the terrace is generally from northeast to southwest. Additional information on this well is included on the attached Well Information Sheet. As shown on the enclosed source water area delineation map, contaminant inventory zones 2 and 3 were delineated using CFR methods. Zone 2 had a calculated radius of 1,244 feet for Well #1 and 1,160 feet for Well #2. Zone 3 had a calculated radius of 1,967 feet for Well #1 and 1,834 feet for Well #2.

Integrity Summary

R Lazy S Ranch uses two wells that are approximately 60 feet deep to supply its water. The wells were constructed between 1983 and 1993 when moderately stringent construction standards were required by the State of Wyoming. Records indicate that the wells may not be properly sealed to protect against surface infiltration of potential contaminants and flooding around the wellhead. The wells also lack adequate protection from contaminant sources in the vicinity immediately around the wellhead. Therefore, as shown on the Integrity Summary Table, both wells received a score of 9.

Water Source Sensitivity Summary

As shown on the Source Sensitivity Summary Table, the wells each received a sensitivity score of 10. The wells received this score for two reasons. First, the wells draw water through porous media flow from an unconfined aquifer that is known to be vulnerable to contamination. The second reason is that there is documented chemical detections in the groundwater.

Water System Susceptibility Rating

Susceptibility is defined as the potential for a public water supply to draw contaminated water at concentrations that would pose a threat or concern to human health. In general, the R Lazy S Ranch scores high for land use susceptibility because much of the land surrounding the water sources is irrigated cropland and used for various other purposes. The overall point source contaminant susceptibility rating is also high due to one permitted underground injection facility within Zone 2 of the water sources. Susceptibility ratings for each type of potential contaminant source are summarized on the attached susceptibility tables.

A review of your PWS's routine water analysis results revealed that one or more chemicals that are considered contaminants in drinking water were detected at some time within the last five years. Chemical detections have a large impact on your PWS's sensitivity score because it may indicate that there is a pathway for contaminants to reach the water supply. However, it is likely that these chemicals are present only in small amounts and are not a danger to your health. Some of these chemicals may also occur naturally in water.

For more information about which chemicals were detected, please contact the PWS for a copy of the most recent Consumer Confidence Report or water analysis results. Chemical detections at levels that are a concern to human health are reported on the EPA's website: http://www.epa.gov/enviro/html/sdwis/sdwis_query.html. To see if your PWS has exceeded the federal primary or secondary drinking water standards, just click on the State of Wyoming and then type in the name of your PWS. Consumer Confidence Reports are prepared by the PWS on a yearly basis. The reports should include information about any chemicals found in the water, even those found at very low levels. Please contact Kim Parker at DEQ, 307-777-7781, or WARWS for assistance. You may also contact EPA to find out what contaminants were detected. You may have to fill out a Freedom of Information Act request to obtain the water test results for your PWS. Please call EPA's Safe Drinking Water Hotline at 1-800-426-4791.

**POINT SUSCEPTIBILITY SUMMARY TABLE
FOR R Lazy S Ranch
Point Source Susceptibility Summary**

It may appear from the results of this point source susceptibility summary table that your system has too many PSOCs influencing the final ratings. In some cases, a specific PSOC falls within a specific contaminant inventory zone shared by multiple wells or intakes. When this is the case, that PSOC will be scored for each intake. For example, an underground storage tank may appear within a contaminant inventory zone shared by four different wells. This would cause that single storage tank to be entered into the table four times, or once for each well or intake.

Point Source Type	Low	Medium	High
Underground Injection	N/A	N/A	2

- * Illustrates the number of PSOCs in a particular rating class for all water sources
- * N/A - Not Applicable