

**SOURCE WATER ASSESSMENT
EXECUTIVE SUMMARY
FOR
Riverside Mobile Home Ct LLC**

June 30, 2004

PROJECT: 424-001

ASSESSMENT COMPLETED BY: TRIHYDRO CORPORATION

1252 Commerce Drive, Laramie, WY 82070



ENGINEERING SOLUTIONS. ADVANCING BUSINESS.

Home Office | 1252 Commerce Drive | Laramie, WY 82070 | phone 307/745.7474 | fax 307/745.7729 | www.trihydro.com

SOURCE WATER ASSESSMENT SUMMARY FOR Riverside Mobile Home Ct LLC

PWS Source Water Assessment Summary

Riverside Mobile Home Court, LLC is a community public water system located in Natrona County. The system serves 155 people through 120 service connections year-round. The system is supplied by two wells that draw from the alluvium along the North Platte River valley. Additionally, facilities include a water treatment pump house and the interconnecting transmission system. Produced water is piped a short distance to the pump house where sodium hypochlorite is added before entry to the distribution system. A linear-chain polymer is also added to remove iron. Two hydropneumatic tanks pressurize the distribution system. There are no additional water storage facilities. The water sources scored medium with respect to the combined integrity and source sensitivity ratings. The mobile home court scored high with respect to land use and low for transportation corridor susceptibility. The mobile home court also scored medium with respect to point source susceptibility.

Delineation Methods

This water system is a community system that draws water from porous alluvium. Groundwater modeling methods were implemented to estimate the 2-year and 5-year time of travel capture zones for the groundwater flow system. The model used well information in the sanitary survey and SEO database. Aquifer parameters used in the model were assumed for those of similar type deposits.

U.S. EPA's Wellhead Analytic Element Model or WhAEM method was used for community water systems that derive their sources from alluvial or shallow bedrock aquifers. The WhAEM model uses well and limited hydrogeologic data to estimate time-of-travel capture zones in relatively simple hydrogeologic settings for either confined or unconfined aquifers. For the source water assessment, the WhAEM model was used to develop two year and five year groundwater capture zones. Due to this methodology, the delineated source water areas may be larger than the true capture zones for each well. However, use of this method typically results in source water protection areas that can be used to more reliably protect the water supply.

Groundwater Sources

The Riverside Mobile Home Court LLC draws water from two wells that draw water from the alluvium along the North Platte River valley. Recharge to the alluvial aquifer comes from the North Platte River, and reaches the wells through porous media flow. Groundwater flow within the alluvium is generally southwest to northeast. Additional information on these wells is included on the attached Well Information Sheet. As shown on the enclosed source water area delineation map, contaminant inventory zones 2 and 3 were delineated using WhAEM methods for both wells. Zones 2 and 3 represent 2-year and 5-year groundwater travel times, respectively. The capture zones extend southwest from the two wellheads.

Integrity Summary

Riverside Mobile Home Court, LLC uses two shallow wells, approximately 53 feet deep, to supply water to the municipal system. The wells were constructed prior to 1983 when less stringent construction standards were required by the State of Wyoming. However, records show that the wells were all properly sealed to protect from surface infiltration of potential contaminants and flooding around the wellhead. As shown on the Integrity Summary Table, the Riverside #1 and #2 wells received scores of 4 due to their well completion dates.

Water Source Sensitivity Summary

As shown on the Source Sensitivity Summary Table, the wells each received a sensitivity score of 10. The wells received the sensitivity score for two reasons. First, the wells are relatively shallow and draw water through porous media flow from an unconfined alluvial aquifer that is known to be vulnerable to contamination. The second reason is that there are documented chemical detections in the groundwater.

Water System Susceptibility Rating

Susceptibility is defined as the potential for a public water supply to draw water contaminated at concentrations that would pose a threat or concern to human health. The Riverside Mobile Home Court LLC scored high for land use susceptibility because much of the land surrounding the wells is urban. The overall point source contaminant susceptibility rating is medium, however, due to 2 potential contaminants located within Zone 2 the rating may be higher. The water sources were assigned a low transportation corridor susceptibility score because their source water zones are in proximity to interstate highways and pipelines. Susceptibility ratings for each type of potential contaminant source are summarized on the attached susceptibility tables.

A review of your PWS's routine water analysis results revealed that one or more chemicals that are considered contaminants in drinking water were detected at some time within the last five years. Chemical detections have a large impact on your PWS's sensitivity score because it may indicate that there is a pathway for contaminants to reach the water supply. However, it is likely that these chemicals are present only in small amounts and are not a danger to your health. Some of these chemicals may also occur naturally in water.

For more information about which chemicals were detected, please contact the PWS for a copy of the most recent Consumer Confidence Report or water analysis results. Chemical detections at levels that are a concern to human health are reported on the EPA's website: http://www.epa.gov/enviro/html/sdwis/sdwis_query.html. To see if your PWS has exceeded the federal primary or secondary drinking water standards, just click on the State of Wyoming and then type in the name of your PWS. Consumer Confidence Reports are prepared by the PWS on a yearly basis. The reports should include information about any chemicals found in the water, even those found at very low levels. Please contact Kim Parker at DEQ, 307-777-7781, or WARWS for assistance. You may also contact EPA to find out what contaminants were detected. You may have to fill out a Freedom of Information Act request to obtain the water test results for your PWS. Please call EPA's Safe Drinking Water Hotline at 1-800-426-4791.

**POINT SUSCEPTIBILITY SUMMARY TABLE
FOR Riverside Mobile Home Ct LLC
Point Source Susceptibility Summary**

It may appear from the results of this point source susceptibility summary table that your system has too many PSOCs influencing the final ratings. In some cases, a specific PSOC falls within a specific contaminant inventory zone shared by multiple wells or intakes. When this is the case, that PSOC will be scored for each intake. For example, an underground storage tank may appear within a contaminant inventory zone shared by four different wells. This would cause that single storage tank to be entered into the table four times, or once for each well or intake.

Point Source Type	Low	Medium	High
Underground Tank	N/A	20	N/A
TRI	N/A	N/A	2
Sol/Haz Waste Site	N/A	10	2

- * Illustrates the number of PSOCs in a particular rating class for all water sources
- * N/A - Not Applicable